

## Bescheinigung zur Nichtrelevanz der ATEX 2014/34/EU Declaration regarding ATEX 2014/34EU not being relevant

**Gerät / Unit:** Druckregler Typ RPM ..  
Pressure regulator Type RPM ..

Die oben bezeichneten Armaturen wurden einem Konformitätsbewertungsverfahren nach der Richtlinie 2014/34/EU mit folgendem Ergebnis unterzogen:

Die Armaturen besitzen keine potentielle Zündquelle und werden manuell betätigt. Die Armaturen fallen nicht in den Anwendungsbereich der ATEX 2014/34/EU.

Die Armaturen dürfen im EX-Bereich Zonen 1 und 2 eingesetzt werden.

Angewendete harmonisierte Normen oder Regelwerke, insbesondere  
AD-2000-Regelwerk  
DIN EN 1127-1  
DIN EN 13463-1

The above mentoined device underwent a hazard analysis according to directive 2014/34/EU with the following result:

The device do not show any potential ignition source and are operated manually.

ATEX 2014/34/EU is thus not applicable to this device

The device may be used in hazardous areas of zone 1and zone 2. Supplementary note:  
AD-2000-Regelwerk  
DIN EN 1127-1  
DIN EN 13463-1

Kassel, den 27.03.2018



i.A. Holger Bürger  
Qualitätssicherung  
Quality Assurance